

PASCHIM GUJARAT VIJ COMPANY LIMITED
COST DATA FOR THE YEAR 2019-20

11 KV/ LT Line on 10 Meter PSC Pole

SR	ITEM CODE	PARTICULARS	UNIT	RATE (Rs.)	SHEET NO.
1	9601000087	TAPPING FROM EXISTING 10 Meter 270 KG PSC POLE FOR 11 KV LINE	NO	7270	10M-1
2	9601000088	DOUBLE POLE STRUCTURE WITH 11 KV A.B.SWITCH & H.G.FUSE ON 10 Meter 270 KG PSC POLE	NO	56141	10M-2
3	9601000089	DOUBLE POLE STRUCTURE WITH 11 KV HG FUSE (WITHOUT AB SWITCH) ON 10 Meter 270 KG PSC POLE	NO	44842	10M-3
4	9601000090	11KV LINE WITH 34 MM2 AAAC CONDUCTOR ON 10 Meter 270 KG PSC POLE WITH WIND PRESSURE 100 KG/M2(SPAN-40 MTR)	KM	331147	10M-4
5	9601000091	11KV LINE WITH 55 MM2 AAAC CONDUCTOR ON 10 Meter 270 KG PSC POLE WITH WIND PRESSURE 100 KG/M2(SPAN-40 MTR)	KM	377517	10M-5
6	9601000092	25 KVA CAPACITY 11 KV/0.433 KV TRANSFORMER CENTRE USING SINGLE POLE STRUCTURE	NO	137469	10M-6
7	9601000093	L.T. LINE 1PH,2 WIRE ON 10 Meter 270 KG PSC POLE WITH VERTICAL FORMATION USING 34 MM2 AAAC CONDUCTOR WITH WIND PRESSURE 100 KG/M2(SPAN-40 MTR)	KM	234727	10M-7
8	9601000094	L.T. LINE 1PH.3 WIRE ON 10 Meter 270 KG PSC POLE WITH VERTICAL FORMATION USING 34 MM2 AAAC CONDUCTOR WITH WIND PRESSURE 100 KG/M2(SPAN-40 MTR)	KM	266823	10M-8
9	9601000095	L.T. LINE 3PH.4 WIRE ON 10 Meter 270 KG PSC POLE WITH VERTICAL FORMATION USING 34 MM2 AAAC CONDUCTOR WITH WIND PRESSURE 100 KG/M2 (SPAN-40 MTR)	KM	341003	10M-9
10	9601000096	1-Ph 5 KVA CAPACITY 11 KV/0.250 KV TRANSFORMER CENTRE USING SINGLE POLE STRUCTURE ON 10 Meter 270 KG PSC POLE	NO	72734	10M-10
11	9601000097	ERECTION OF PSC POLE 10M/ 270 KG UNDER EXISTING 11KV LINE WITH WIND PRESSURE 100 KG/M2	NO	9273	10M-11